



**KEYNOTES:**

- A. CLASS "B" 3/4"-0" CRUSHED ROCK GRANULAR BACKFILL COMPACTED TO 95% OF AASHTO T-99
- B. CLASS "A" NATIVE BACKFILL COMPACTED TO 90% OF AASHTO T-99 IN LIFTS NOT EXCEEDING 18" (LOOSE MEASURE)

**GENERAL NOTES:**

- 1. SAWCUT WIDTH AND AC PAVEMENT REPLACEMENT SHALL BE PER APPLICABLE JURISDICTIONAL REQUIREMENTS.
- 2. IF THESE SPECIFICATIONS CONFLICT WITH THE SPECIFICATIONS OF ANOTHER APPLICABLE JURISDICTION, THE MORE STRINGENT SPECIFICATION SHALL GOVERN.
- 3. 36" MINIMUM COVER IS REQUIRED. COVER DEEPER THAN 36" SHALL BE APPROVED BY DISTRICT ENGINEER.

N:\Standards\2024\Details\DWG\201\_Typical Trench Backfill.dwg, 6/13/2024 10:43:28 AM



**TUALATIN VALLEY  
WATER DISTRICT**

APPROVED BY  
PETER BOONE

DRAWING SCALE  
NONE

TYPICAL TRENCH BACKFILL

EFF. DATE 07/01/24

STANDARD DETAIL

201